

POTENCIAS DE CORTOCIRCUITO EN BARRAS FRONTERA 132 KV - CIRCUITO EQUIVALENTE

POTENCIA BASE: 100 MVA (Sb)

BARRA	2015				2016				2017				2018				2019			
	TRI MVA	MONO MVA	Z+ %	Z0 %	TRI MVA	MONO MVA	Z+ %	Z0 %	TRI MVA	MONO MVA	Z+ %	Z0 %	TRI MVA	MONO MVA	Z+ %	Z0 %	TRI MVA	MONO MVA	Z+ %	Z0 %
PUELCHES 132	721	885	15,26	6,77	715	878	15,38	6,82	719	883	15,30	6,77	734	902	14,99	6,61	735	902	14,97	6,65
MACACHÍN 132	930	995	11,83	9,51	932	997	11,80	9,49	929	993	11,84	9,55	951	1010	11,57	9,54	955	1013	11,52	9,54
PIGÜÉ 132	629	545	17,49	25,57	631	545	17,43	25,69	628	542	17,52	25,85	636	546	17,30	25,85	747	610	14,73	24,65
PUAN 132	497	359	22,13	47,66	498	359	22,09	47,75	495	356	22,22	48,25	500	358	22,00	48,18	549	379	20,04	47,00
T.LAUQUEN 132	586	564	18,77	20,97	586	562	18,77	21,18	583	562	18,87	20,98	637	596	17,27	20,83	636	595	17,30	20,87
H. RENANCÓ 132	272	287	40,44	34,10	272	287	40,44	34,10	272	287	40,44	34,10	272	287	40,44	34,10	272	287	40,44	34,10
STO. ANDERSEN	424	349	25,94	42,67	424	349	25,94	42,67	424	349	25,94	42,67	424	349	25,94	42,67	424	349	25,94	42,67
CHARLONE													1586	1816	6,94	4,30	2804	2762	3,92	4,10