

**INDISPONIBILIDADES PUNTOS DE TRAFOS - CALIDAD DE SERVICIO - AÑO 2012**

idtrafo	estacion	trafo	nro_forz	hrs_forz	nro_forz_aut	hrs_forz_aut	nro_prog	hrs_prog
1	ANCHORIS	ANCH 132/66/13. ATR1	4	55,38	0	0	4	15,4
2	ANCHORIS	ANCH 132/66/13. ATR2	1	4,05	1	0,8	4	19,07
3	BAJO R.TUNUYAN	TUNUY 132/66/13. ATR1	1	2,68	0	0	1	35,43
4	BAJO R.TUNUYAN	TUNUY 132/66/13. ATR2	1	2,7	0	0	1	33,98
5	BAJO R.TUNUYAN	TUNUY 66/13.2 TR1	0	0	0	0	0	0
34	CAÑADA HONDA	CAÑADA HONDA TRAF0 1	3	3,78	0	0	3	20,54
6	CAPIZ	CAPIZ 132/66/13. TR1	0	0	0	0	1	4,78
	CAPIZ	CAPIZ 132/66/13. TR3	2	3,77	0	0	2	12,2
7	CAPIZ	CAPIZ 132/66/13. TR2	0	0	0	0	3	11,75
10	CRUZ DE PIEDRA	CZPIE 13.2/13.2 TR aislación	5	45,6	0	0	2	12,5
11	CRUZ DE PIEDRA	CZPIE 132/66/13. TR3	0	0	0	0	2	11,41
12	CRUZ DE PIEDRA	CZPIE 132/66/13. TR2	0	0	0	0	2	13,52
33	CRUZ DE PIEDRA	CZPIE 132/66. TR 5	0	0	0	0	0	0
8	CRUZ DE PIEDRA	CZPIE 220/132 ATR1	1	0,15	0	0	1	3,43
9	CRUZ DE PIEDRA	CZPIE 220/132 ATR2	0	0	1	3,13	2	9,58
15	LUJAN DE CUYO	LCUYO 132/13.2 TR17	0	0	1	0,97	0	0
16	LUJAN DE CUYO	LCUYO 132/13.2 TR18	0	0	0	0	1	8,9
13	LUJAN DE CUYO	LCUYO 132/33/13. TR5	0	0	0	0	3	18,05
14	LUJAN DE CUYO	LCUYO 132/33/13. TR6	0	0	1	6	8	42,37
17	LUJAN DE CUYO	LCUYO SILARSA/TR TR	2	7,57	0	0	1	8,9
18	MONTECASEROS	MCASMZA 132/66/13.ATR1	0	0	0	0	1	7,68
19	MONTECASEROS	MCASMZA 132/66/13.ATR2	0	0	0	0	1	6,5
39	MONTECASEROS	MCASMZA 132/66/13. ATR3	0	0	0	0	4	11,12
38	SAN JUAN	SAN JUAN 132/33/13. TR2	0	0	0	0	3	20,07
23	SAN JUAN	SJUAN 132/33/13.N TR5	1	0,05	0	0	2	18,08

22	<b>SAN JUAN</b>	<b>SJUAN 132/33/13. TR1</b>	1	186,1	0	0	2	18,,06
24	<b>SAN JUAN</b>	<b>SJUAN 132/33/13. TR3 SW</b>	0	0	0	0	2	18,08
25	<b>SAN JUAN</b>	<b>SJUAN 132/33 TR4</b>	0	0	0	0	2	20,77
20	<b>SAN JUAN</b>	<b>SJUAN 220/132 ATR1</b>	0	0	0	0	0	0
27	<b>SAN JUAN</b>	<b>SJUAN 220/132 ATR2</b>	0	0	0	0	2	25,95

Hasta

30/11/2012